



Summit County Public Health

1867 West Market Street ♦ Akron, Ohio 44313-6901

Phone: (330) 926-5600 ♦ Toll-free: 1 (877) 687-0002 ♦ Fax: (330) 923-6436

www.scphoh.org

Reasons to Close a Pool or Spa:

Ohio Administrative Code 3701-31-04: Responsibilities of the licensee:

Operations. The licensee of a public swimming pool shall maintain the pool, its components, appurtenant facilities and the surrounding area in a safe, clean and sanitary condition, in good repair and in accordance with this chapter.

Critical operational items. The licensee **shall not operate** a public swimming pool or portion thereof when an imminent health hazard is present, including but not limited to the following:

- a. When a main drain cover is not properly installed, securely fastened or in compliance with current standards.
- b. When a safety vacuum release system is not functioning.
- c. When the disinfectant residual is less than what is required.
- d. When the circulation and/or disinfection system is not operating properly.
- e. When an automatic chemical controller is not functioning.
- f. When a lifeguard is not provided as is required.
- g. When water clarity is insufficient.
- h. When lighting (natural or artificial) is insufficient to see the bottom of the pool.
- i. When a fecal accident has occurred, until it has been properly treated.
- j. When a recreational waterborne illness is linked to a pool.
- k. When chemical storage is improper, posing an imminent health hazard.
- l. When there is an electrical hazard.